



CONSTRUCTION NOTES:

- ① 8" 45° Bend, SDR-35 PVC or VCP, bell end x spigot end.
- ② 8" SDR-35 PVC or VCP sewer pipe, bell and spigot end.
- ③ Cleanout cover shall be constructed per applicable portions of STD-511-L. Alhambra Foundry A-1244.
- ④ 8" Rubber mechanical banded seal coupling; stainless steel bands; Fernco or City approved equivalent.
- ⑤ Install ABS stopper in rubber coupling. Use Mission Clay Products stopper or approved equal.

GENERAL NOTES:

- 1. Backfill material shall be compacted to 95% of optimum with 3/4" aggregate base rock material.
- 2. Sewer cleanout cover shall be marked "Sewer" on the triangular lid new r/c style Alhambra Foundry A-1244.
- 3. SDR-35 PVC pipe shall be used when the sewer main is PVC, and VCP shall be used when the sewer main is VCP.
- 4. 12" x 6" min. thickness conc. collar.

CITY OF NEWPORT BEACH
PUBLIC WORKS DEPARTMENT

**SEWER MAIN
TERMINAL CLEANOUT**

APPROVED:



RCE NO. 36106

PUBLIC WORKS DIRECTOR

Drawn: M. Elias

Scale: N.T.S.

Date: Jan. 2004

F:\USERS\PBW\Shared\CAD STD\STD Details\2003_Std\STD Sewer

DRAWING NO.

STD-400-L