



- NOTES:**
1. REINFORCING STEEL SHALL BE STRAIGHT BARS 1-1/2" CLEAR FROM FACE OF CONCRETE.
 2. P-DEPTH P MAY BE REDUCED TO AN ABSOLUTE LIMIT OF 6" WHEN LARGER VALUES OF P WOULD REDUCE H TO 3'-6" OR LESS.
 3. STATIONS OF MANHOLES SHOWN ON PLAN APPLY AT CENTERLINE OF SHAFT. ELEVATIONS ARE SHOWN AT SHAFT CENTER AND REFER TO THE PROLONGED INVERT GRADE LINE.

H	t
UNDER 8'	8"
8'-1" & OVER	10"

REF. STD.-112-L; STD.-404-L
 ADOPTED FROM LACDPW STD. DWG. NO. 3020-0 REV. 9/93

CITY OF NEWPORT BEACH
 PUBLIC WORKS DEPARTMENT

JUNCTION STRUCTURE
 NO. 1

APPROVED:

DIRECTOR OF PUBLIC WORKS
 R.C.E. NO. 12806

DATE 15 Nov 1993 SCALE N.T.S.
 DRAWN M. GRACIA STD-310-L