

**City of Newport Beach - Building Department**

-

**ELECTRICAL CODE POLICY**

| <b>Effective Date</b> | <b>Subject</b>   | <b>Policy No.</b>    |
|-----------------------|--|----------------------|
| November 9, 1999      | Intermediate and Rigid Metal Conduit Installed in Contact with Earth | N.E.C. 345-3b; 346-1 |

Due to unusually corrosive soil conditions that exist within the City of Newport Beach, intermediate and rigid metal conduit is prohibited where installed in direct contact with the earth.

---

Jay Elbetta, Building Director