



PIPE SLOPE	X DISTANCE
1:1	12'
1-1/2:1	14'
2:1	16'
2-1/2:1	18'
3:1	20'

CONCRETE PIPE ANCHORS

NOTES:

1. PIPE ANCHORS REQUIRED ON ALL SLOPES OF 3:1 OR STEEPER.
2. ALL REINFORCING STEEL SHALL BE EPOXY-COATED NUMBER 4 BARS. EXPOSED CUT ENDS SHALL BE SPRAYED WITH EPOXY COATING.
3. "E" SHALL BE 8" UNLESS OTHERWISE SPECIFIED.

ADOPTED FROM L.A.C. STD. PLAN S-251-1

FORMER CITY STANDARD PLAN NUMBER (2004 EDITION): STD 314-L

APP.	51568 RCE	11/24/2020 DATE	
CITY ENGINEER	RCE	DATE	NO. DATE DESCRIPTION OF REVISIONS

CITY OF NEWPORT BEACH DEPARTMENT OF PUBLIC WORKS

DRAWN: M. ELIAS	<h1>CONCRETE PIPE SLOPE ANCHORS</h1>	<h2>325</h2>
DATE: 11/3/2020		STANDARD DRAWING NO. SHEET 1 OF 1