

**City of Newport Beach - Building Department**

-

**ELECTRICAL CODE POLICY**

<b>Effective Date</b>	<b>Subject</b>	<b>Policy No.</b>
November 9, 1999	Flexible Metal Conduit as a Grounding Means	N.E.C. 350-14

Due to corrosive salt air conditions found within the City, it is the policy of the City of Newport Beach that all flexible metal conduit shall have a separate ground wire installed regardless on the length of the conduit.

---

Jay Elbetta, Building Director