


Property Information			Contractor or Licensed Owner Information		
Building Name			Name		
Address		Address			
City		City	St.	Zip	
Contact Person		License #	Phone		
Phone		<input type="checkbox"/> SFM	Job #		
		<input type="checkbox"/> CSLB	Misc.		

This building has more than 5 risers. See additional AES 2.9 form attached Number of AES 2.9 forms attached

INSPECTION, TESTING, AND MAINTENANCE

I = Inspection T = Test M = Maintenance *P = Pass F = Fail N/A = Not Applicable*

Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
Inspection						
1.1	I	Backflow Preventer	Chapter 13			
1.2	I	Check Valves	Chapter 13			
1.3	I	Control Valves (sealed)	Chapter 13			
1.4	I	Control Valves (locked, supervised)	Chapter 13			
1.5	I	Deluge Valve	10.2.2, Chapter 13			
1.6	I	Detection Systems	NFPA 72			
1.7	I	Detector Check Valves	Chapter 13			
1.8	I	Drainage	10.2.8			
1.9	I	Electric Motor	10.2.9 Chapter 8			
1.10	I	Engine Drive	10.2.9 Chapter 8			
1.11	I	Fire Pump	10.2.9 Chapter 8			
1.12	I	Fittings	10.2.4, 10.2.4.1			
1.13	I	Fittings (rubber gasketed)	10.2.3.1, Annex			
1.14	I	Gravity Tanks	10.2.10, Chapter 9			
1.15	I	Hangers	10.2.4.2			
1.16	I	Heat (Deluge Valve House)	10.2.1.5 Chapter 13			
1.17	I	Nozzles	10.2.1.1, 10.2.1.2, 10.2.1.6, 10.2.5.1, 10.2.5.2			
1.18	I	Pipe	10.2.1.1, 10.2.1.2, 10.2.4, 10.2.4.1,			
1.19	I	Pressure Tank	10.2.10, Chapter 9			

Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Job #
City		

INSPECTION, TESTING, AND MAINTENANCE

I = Inspection T = Test M = Maintenance

P = Pass F = Fail N/A = Not Applicable

Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
1.20	I	Steam Driver	10.2.9, Chapter 8			
1.21	I	Strainers	10.2.7			
1.22	I	Suction Tanks	10.2.10, Chapter 9			
1.23	I	Supports	10.2.1.1, 10.2.1.2, 10.2.4.2			
1.24	I	Water Flow Alarm Devices	NFPA 72			
1.25	I	Water Supervisory Alarm Devices	NFPA 72			
1.26	I	Supervisory Signal Devices (except valve supervisory switches)	NFPA 72			
1.27	I	Water Supply Piping	10.2.6.1 10.2.6.2			
1.28	I	UHSWSS-Detectors	10.4.2			
1.29	I	UHSWSS-Controllers	10.4.3			
1.30	I	UHSWSS-Valves	10.4.4			
		Test				
2.0	T	Backflow Preventer	Chapter 13			
2.1	T	Check Valves	Chapter 13			
2.2	T	Control Valves	13.3.3.1			
2.	T	Deluge Valve	10.2.2, Chapter 13			
2.4	T	Detection Systems	NFPA 72			
2.5	T	Detector Check Valve	Chapter 13			
2.6	T	Electric Motor	10.2.0, Chapter 13			
2.7	T	Engine Drive	10.2.9, Chapter 8			
2.8	T	Fire Pump	10.2.9, Chapter 8			
2.9	T	Flushing Connection to Riser (part of annual test)	10.2.1.3, Section 10.3			
2.10	T	Gravity Tanks	10.2.10, Chapter 9			
2.11	T	Main Drain Test	13.3.3.4			
2.12	T	Manual Release	10.2.1.3, 10.3.6			

Property Information		Contractor or Licensed Owner Information	
Building Name		Name	
Address		Job #	
City			

INSPECTION, TESTING, AND MAINTENANCE

I = Inspection T = Test M = Maintenance

P = Pass F = Fail N/A = Not Applicable

Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
2.13	T	Nozzles	10.2.1.3, 10.2.1.6, Section 10.3			
2.14	T	Pressure Tank	Section 10.2, Chapter 9			
2.15	T	Steam Driver	10.2.9, Chapter 8			
2.16	T	Strainers	10.2.1.3, 10.2.1.7, 10.2.7			
2.17	T	Suction Tanks	10.2.10, Chapter 9			
2.18	T	Water Flow Alarm	Chapter 5			
2.19	T	Valve Supervisory Signal Devices	Chapter 13			
2.20	T	Supervisory Signal Devices (Except Valve Supervisory Switches)	13.2.6.2			
2.21	T	Water Spray System Test	10.3, Chapter 13			
2.22	T	Water Supply Flow Test	7.3.1			
2.23	T	UHSWSS	10.4			
		Maintenance				
3.0	M	Backflow Preventer	Chapter 13			
3.1	M	Check Valves	Chapter 13			
3.2	M	Control Valves	10.2.1.4, Chapter 13			
3.3	M	Deluge Valve	10.2.2, Chapter 13			
3.4	M	Detection Systems	NFPA 72			
3.5	M	Detector Check Valve	Chapter 13			
3.6	M	Electric Motor	10.2.9, Chapter 8			
3.7	M	Engine Drive	10.2.9, Chapter 8			
3.8	M	Fire Pump	10.2.9, Chapter 8			
3.9	M	Gravity Tanks	10.2.10, Chapter 9			
3.10	M	Pressure Tanks	10.2.6, Chapter 9			
3.11	M	Steam Driver	10.2.9, Chapter 8			

Property Information		Contractor or Licensed Owner Information
Building Name		Name
Address		Job #
City		

INSPECTION, TESTING, AND MAINTENANCE

I = Inspection T = Test M = Maintenance P = Pass F = Fail N/A = Not Applicable

Item		Description	NFPA 25 CA ed. Reference	Date	Comments Only	P,F,N/A
3.12	M	Strainers	10.2.1.4, 10.2.1.6, 10.2.7			
3.13	M	Strainers - Baskets/Screen	10.2.1.4, 10.2.1.7, A10.2.7			
3.14	M	Suction Tanks	10.2.10, Chapter 9			
3.15	M	Water Spray System	10.2.1.4, Chapter 13			

D = Deficiency C = Comment (Indicate type)

Item	Date	Riser	D	C	Deficiencies and Comments <small>Indicate all equipment, devices and parts that were repaired or replaced</small>

Check here if additional Deficiencies and Comments are listed on Form AES9 Number attached: _____
 See Correction Form AES 10 for corrected deficiencies. Number attached: _____

I hereby certify that the fire protection equipment listed above has been fully inspected, tested, and maintained on this date by the company indicated above, in accordance with CCR, Title 19, Sections 901 to906 and that the equipment is fully operable except as noted in the "Deficiencies and Comments" section of this form.

Print Name	
Signature	Date