

NOVEMBER, 2025	PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	*Tamura Shallow	Tamura Deep
PFOA	ND	ND	ND	2 ppt	ND
PFOS	ND	2.7 ppt	ND	6.5 ppt	ND
PFHxS	ND	4.8 ppt	ND	6.4 ppt	ND

JULY, 2025	PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	*Tamura Shallow	Tamura Deep
PFOA	ND	ND	ND	Out of Srvc	ND
PFOS	ND	2.7 ppt	ND	Out of Srvc	ND
PFHxS	ND	4.8 ppt	ND	Out of Srvc	ND

**Tamura Shallow Out of Service for maintenance, no testing.*

APRIL, 2025	PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	*Tamura Shallow	Tamura Deep
PFOA	ND	ND	ND	Out of Srvc	ND
PFOS	ND	2.7 ppt	ND	Out of Srvc	ND
PFHxS	ND	4.6 ppt	ND	Out of Srvc	ND

**Tamura Shallow Out of Service for maintenance, no testing.*

JANUARY, 2025	PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	*Tamura Shallow	Tamura Deep
PFOA	ND	ND	ND	Out of Srvc	ND
PFOS	ND	2.7 ppt	ND	Out of Srvc	ND
PFHxS	ND	4.3 ppt	ND	Out of Srvc	ND

**Tamura Shallow Out of Service for maintenance, no testing.*

NOVEMBER, 2024	PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	Tamura Shallow	Tamura Deep
PFOA	ND	ND	ND	ND	ND
PFOS	ND	2.8 ppt	ND	5.6 ppt	ND
PFHxS	ND	4.2 ppt	ND	4.8 ppt	ND

JULY, 2024	PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	Tamura Shallow	Tamura Deep
PFOA	ND	ND	ND	ND	ND
PFOS	ND	2.1 ppt	ND	4.5 ppt	ND
PFHxS	ND	3.8 ppt	ND	4.6 ppt	ND