

OCTOBER, 2025		PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	Tamura Shallow	Tamura Deep	
PFOA	ND	ND	ND	2.1 ppt	ND	
PFOS	ND	3.0 ppt	ND	7.0 ppt	ND	
PFHxS	ND	5.6 ppt	ND	7.1 ppt	ND	

JULY, 2025		PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	Tamura Shallow	Tamura Deep	
PFOA	ND	ND	ND	2 ppt	ND	
PFOS	ND	2.7 ppt	ND	6.5 ppt	ND	
PFHxS	ND	4.8 ppt	ND	6.4 ppt	ND	

APRIL, 2025		PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	*Tamura Shallow	Tamura Deep	
PFOA	ND	ND	ND	Out of Srvc	ND	
PFOS	ND	2.7 ppt	ND	Out of Srvc	ND	
PFHxS	ND	4.6 ppt	ND	Out of Srvc	ND	

\*Tamura Shallow Out of Service for maintenance, no testing.

JANUARY, 2025		PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	*Tamura Shallow	Tamura Deep	
PFOA	ND	ND	ND	Out of Srvc	ND	
PFOS	ND	2.7 ppt	ND	Out of Srvc	ND	
PFHxS	ND	4.3 ppt	ND	Out of Srvc	ND	

\*Tamura Shallow Out of Service for maintenance, no testing.

NOVEMBER, 2024		PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	Tamura Shallow	Tamura Deep	
PFOA	ND	ND	ND	ND	ND	
PFOS	ND	2.8 ppt	ND	5.6 ppt	ND	
PFHxS	ND	4.2 ppt	ND	4.8 ppt	ND	

JULY, 2024		PFAS Quarterly Testing Results				
PFAS Compounds Tested	16th Street Reservoir	Dolphin Shallow	Dolphin Deep	Tamura Shallow	Tamura Deep	
PFOA	ND	ND	ND	ND	ND	
PFOS	ND	2.1 ppt	ND	4.5 ppt	ND	
PFHxS	ND	3.8 ppt	ND	4.6 ppt	ND	