



Not to scale

GENERAL NOTES:

1. Meter boxes shall be placed such that space between boxes is a minimum of 4 inches.
2. Where practical, a concrete slab shall be poured around and between meter boxes.
3. Refer to STD-516-L for multiple water service connections to the main.
4. Concrete meter box shall be from the following:
 For 1" meters: For 2" meters:
 Eisle #437 Eisle #655½
5. Meter boxes subject to traffic loading shall have cast iron covers.

CITY OF NEWPORT BEACH
PUBLIC WORKS DEPARTMENT

**Multiple Water Meter &
Service Box Installations**

APPROVED:



RCE NO. 36106

PUBLIC WORKS DIRECTOR

Drawn: M. Elias

Scale: N.T.S.

Date: Jan. 2004

F:\USERS\PBW\Shared\CAD STD\STD Details\2003 - Std\STD Water

DRAWING NO.

STD-518-L